



THE STATE  
of **ALASKA**  
GOVERNOR MICHAEL J. DUNLEAVY

**Department of Environmental  
Conservation**

DIVISION OF ENVIRONMENTAL HEALTH  
Drinking Water Program

555 Cordova Street  
Anchorage, Alaska 99501  
Direct: 907.269-7653  
Fax: 907.269-7650  
Leah.vansandt@alaska.gov

August 30, 2022

Mr. Phil Zavadil  
City Manager  
P.O. Box 901  
Saint Paul, AK 99660  
Email: [pazavadil@stpaulak.com](mailto:pazavadil@stpaulak.com)

RE: Rescind Boil Water Notice for Saint Paul, PWSID AK2260286, Effective 8/30/2022  
Community Public Water System, Groundwater Sources

Dear Mr. Zavadil,

On 8/26/2022, the Department issued a Boil Water Notice to Saint Paul public water system, ID# 260286, due to reported water main break and water pressure loss/reduction below 20 psi. After repairs and required disinfection and flushing, special coliform samples were monitored from the impacted areas. On 8/30/2022, our department received lab results of the three coliform samples monitored from the representative sites of Saint Paul distribution system. Results are all negative for coliform bacteria. Also, the reported water pressure is reliably above 20 psi.

**Based on this information, we are rescinding the Boil Water Notice, effective immediately.**

We appreciate your administration's prompt actions to resolve this matter and to protect the public health by serving safe drinking water.

If you have questions regarding this letter, please contact me at 907-269-7653 or by email at [leah.vansandt@alaska.gov](mailto:leah.vansandt@alaska.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "Leah A. Van Sandt".

Leah A. Van Sandt  
Environmental Program Specialist

Cc: Heather Murray, DEC/DW Southcentral Program Manager, [heather.murray@alaska.gov](mailto:heather.murray@alaska.gov)  
DEC BWN email group